

**CITY OF LANCASTER
BUREAU OF WATER
CHEMISTRY & MICROBIOLOGY LABORATORIES**



2020 DRINKING WATER ANALYSIS REPORT

TABLE OF CONTENTS

ANALYSIS	PAGE
INORGANIC	1
CHLORINE, TURBIDITY, MICROBIOLOGICAL TRICHALOMETHANES, HALOACETIC ACIDS	2
SECONDARY CONTAMINANTS, OTHER TESTS	3
VOLATILE ORGANIC CHEMICALS	4
SYNTHETIC ORGANIC CHEMICALS	5
ABBREVIATIONS	6

CITY OF LANCASTER

DRINKING WATER ANALYSIS REPORT

PA DEPARTMENT OF ENVIRONMENTAL PROTECTION - PRIMARY CONTAMINANT LIST

INORGANIC

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>		<u>SUSQUEHANNA PLANT</u>		<u>PA DEP MCL</u>	
ANTIMONY	ND	mg/L	ND	mg/L	0.006	mg/L
ARSENIC	ND	"	ND	"	0.01	"
BARIUM	0.053	mg/L	0.027	mg/L	2	mg/L
BERYLLIUM	ND	"	ND	"	0.004	mg/L
CADMIUM	ND	"	ND	"	0.005	"
CHROMIUM	0.002	"	ND	"	0.1	"
COPPER	0.16	"	0.16	"	1.3	"
CYANIDE, Free	ND	"	ND	"	0.2	"
FLUORIDE	0.60	"	0.61	"	2.0	"
LEAD **	0.0057	"	0.0057	"	0.015	"
MERCURY	ND	"	ND	"	0.002	"
NICKEL	ND	"	0.001	"	0.1	"
NITRATE	5.7	"	ND	"	10	"
SELENIUM	ND	"	ND	"	0.05	"
THALLIUM	ND	"	ND	"	0.002	"

* Testing for presence of Marcellus shale "frack" water in Susquehanna Treatment Plant raw water.

** Lead Levels from High Risk Homes in the Distribution System: 90th Percentile = 0.006 mg/L. Tested in 2019.

CITY OF LANCASTER

DRINKING WATER ANALYSIS REPORT

PA DEPARTMENT OF ENVIRONMENTAL PROTECTION - PRIMARY CONTAMINANT LIST

CHLORINE

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>	<u>OYSTER POINT RESERVOIR</u>	<u>DEP MCL</u>	
CHLORINE, Free Residual	1.26	1.1	4.0	mg/L

TURBIDITY

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>	<u>SUSQUEHANNA PLANT</u>	<u>PA DEP MCL</u>	
TURBIDITY, Combined Effluent	0.01	NTU	0.01	NTU
			0.15	NTU

MICROBIOLOGICAL

	<u>RESULT</u>	<u>DEP TT</u>
TOTAL COLIFORM*	0.00%	<5% POSITIVES/MONTH

	<u>RESULT</u>	<u>PA DEP MCL</u>
ESCHERICHIA COLI*	0	0 POSITIVES/MONTH

TRIHALOMETHANES

	<u>RESULT</u>	<u>PA DEP MCL</u>
TRIHALOMETHANES, TOTAL *	57.8	80
(Highest 12 Month Locational Running Annual Average)	µg/L	µg/L

HALOACETIC ACIDS

	<u>RESULT</u>	<u>PA DEP MCL</u>
HALOACETIC ACIDS, TOTAL *	37	60
(Highest 12 Month Locational Running Annual Average)	µg/L	µg/L

* Results are from samples taken in the distribution system

CITY OF LANCASTER

DRINKING WATER ANALYSIS REPORT

PA DEPARTMENT OF ENVIRONMENTAL PROTECTION - SECONDARY CONTAMINANT LIST

SECONDARY

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>		<u>SUSQUEHANNA PLANT</u>		<u>PA DEP SMCL</u>	
ALUMINUM, Total	0.05	mg/L	0.05	mg/L	0.05	mg/L
CHLORIDE	30.5	"	25	"	250	"
COLOR	0.6	CU	0.8	CU	15	CU
IRON, Total	0.02	mg/L	0.02	mg/L	0.3	mg/L
MANGANESE, Total	0.024	"	0.018	"	0.05	"
pH	7.4	SU	7.4	SU	6.5-8.5	SU
SULFATE	42	mg/L	39	mg/L	250	mg/L

OTHER TESTS

	<u>CONESTOGA PLANT</u>		<u>SUSQUEHANNA PLANT</u>		<u>PA DEP Range</u>	
ALKALINITY	149	mg/L	61	mg/L	NS	mg/L
HARDNESS, milligrams/liter	208	"	103	"	NS	"
HARDNESS, grains/gallon	12	GPG	6	GPG	NS	GPG
ORGANIC CARBON, Total	2.1	mg/L	1.6	mg/L	NS	mg/L
PHOSPHATE, Ortho	0.21	mg/L	0.22	mg/L	0.13-0.33	"
SPECIFIC CONDUCTANCE	558	µS/cm	327	µS/cm	NS	µS/cm

CITY OF LANCASTER

DRINKING WATER ANALYSIS REPORT

PA DEPARTMENT OF ENVIRONMENTAL PROTECTION - VOLATILE ORGANIC CHEMICAL LIST

VOLATILE ORGANIC CHEMICALS

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>		<u>SUSQUEHANNA PLANT</u>		<u>PA DEP MCL</u>	
BENZENE	ND	mg/L	ND	mg/L	0.005	mg/L
CARBON TETRACHLORIDE	ND	"	ND	"	0.005	"
CHLOROBENZENE	ND	"	ND	"	0.1	"
1,2-DICHLOROBENZENE	ND	"	ND	"	0.6	"
1,4 - DICHLOROBENZENE	ND	"	ND	"	0.075	"
1,2-DICHLOROETHANE	ND	"	ND	"	0.005	"
1,1-DICHLOROETHENE	ND	"	ND	"	0.007	"
cis-1,2,-DICHLOROETHYLENE	ND	"	ND	"	0.07	"
trans-1,2,-DICHLOROETHENE	ND	"	ND	"	0.1	"
1,2-DICHLOROPROPANE	ND	"	ND	"	0.005	"
ETHYLBENZENE	ND	"	ND	"	0.7	"
METHYLENE CHLORIDE	ND	"	ND	"	0.005	"
STYRENE	ND	"	ND	"	0.1	"
TETRACHLOROETHENE	ND	"	ND	"	0.005	"
TOLUENE	ND	"	ND	"	1	"
1,2,4-TRICHLOROBENZENE	ND	"	ND	"	0.07	"
1,1,1-TRICHLOROETHANE	ND	"	ND	"	0.2	"
1,1,2-TRICHLOROETHANE	ND	"	ND	"	0.005	"
TRICHLOROETHENE	ND	"	ND	"	0.005	"
VINYL CHLORIDE	ND	"	ND	"	0.002	"
XYLENES (total)	ND	"	ND	"	10	"

CITY OF LANCASTER
DRINKING WATER ANALYSIS REPORT

PA DEPARTMENT OF ENVIRONMENTAL PROTECTION - SYNTHETIC ORGANIC CHEMICAL LIST

SYNTHETIC ORGANIC CHEMICALS

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>		<u>SUSQUEHANNA PLANT</u>		<u>DEP MCL</u>	
ALACHLOR	ND	mg/L	ND	mg/L	0.002	mg/L
ALDICARB	ND	"	ND	"	0.003	"
ALDICARB SULFOXIDE	ND	"	ND	"	0.004	"
ALDICARB SULFONE	ND	"	ND	"	0.002	"
ATRAZINE	ND	"	ND	"	0.003	"
BENZO(a)PYRENE	ND	"	ND	"	0.0002	"
CARBARYL	ND	"	ND	"	NS	"
CARBOFURAN	ND	"	ND	"	0.04	"
CHLORDANE	ND	"	ND	"	0.002	"
DALAPON	ND	"	ND	"	0.2	"
DIBROMOCHLOROPROPANE	ND	"	ND	"	0.0002	"
BIS(2-ETHYLHEXYL)ADIPHATE	ND	"	ND	"	0.4	"
BIS(2-ETHYLHEXYL)PHTHALATE	ND	"	ND	"	0.006	"
DICAMBA	ND	"	ND	"	0.2	"
DINOSEB	ND	"	ND	"	0.007	"
DIQUAT	ND	"	ND	"	0.02	"
ENDOTHALL	ND	"	ND	"	0.1	"
ENDRIN	ND	"	ND	"	0.0002	"
ETHYLENE DIBROMIDE (EDB)	ND	"	ND	"	0.00005	"
GLYCOPHOSPHATE	ND	"	ND	"	0.7	"
HEPTACHLOR	ND	"	ND	"	0.0004	"
HEPTACHLOR EPOXIDE	ND	"	ND	"	0.0002	"
HEXACHLOROCYCLOPENTADIENE	ND	"	ND	"	0.05	"
3-HYDROXYCARBOFURAN	ND	"	ND	"	NS	"
LINDANE	ND	"	ND	"	0.0002	"
METHOMYL	ND	"	ND	"	NS	"
METHOXYCHLOR	ND	"	ND	"	0.04	"
METOLACHLOR	ND	"	ND	"	0.2	"
METRIBUXIN	ND	"	ND	"	0.2	"
OXAMYL (Vydate)	ND	"	ND	"	0.2	"
PENTACHLOROPHENOL	ND	"	ND	"	0.001	"
PICLORAM	ND	"	ND	"	0.5	"
PROPACHLOR	ND	"	ND	"	NS	"
SIMAZINE	ND	"	ND	"	0.004	"
2,4-D	ND	"	ND	"	0.07	"
2,4,5-TP (SILVEX)	ND	"	ND	"	0.05	"
2,3,7,8-TCDD (DIOXIN)	ND	"	ND	"	0.00000003	"

CITY OF LANCASTER

DRINKING WATER ANALYSIS REPORT

ABBREVIATIONS

- | | |
|---------------------------------|-------------------------------------|
| °C - DEGREES CENTIGRADE | ND - NOT DETECTED |
| cm - CENTIMETER | NS - NO STANDARD |
| CU - COLOR UNIT | NT - NO TEST |
| HPC - HETEROTROPHIC PLATE COUNT | NTU - NEPHELOMETRIC TURBIDITY UNIT |
| Mg/L - MILLIGRAMS/LITER | TT - TREATMENT TECHNIQUE REQUIRMENT |
| mL - MILLILITER | WL - WORKING LEVEL |
| pCi/L - PICOCURIES/LITER | < - LESS THAN |
- MF/L - MILLION FIBERS PER LITER, LESS THAN 10 MICROMETERS LONG (ASBESTOS)
- µS/cm - MICRO SEIMENS PER CENTIMETER
- PA DEP - PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
- MCL - MAXIMUM CONTAMINANT LEVEL
- SMCL - SECONDARY MAXIMUM CONTAMINANT LEVEL, Not Legally Enforceable